

REQUEST FOR INFORMATION LOG

Project: *City of Cottondale - Hurricane Michale Recovery Projects*

RFI #	Request By	Discipline	Question	Response	Response by	Response Date
1	GCUC	Grant	What are the liquidated damages for this project?	\$425 per day	Hunter Potts, DHM	12/22/25
2	GCUC	Grant	Will this project require Davis Bacon?	All project parts require Davis Bacon minus the RIF Grant funded parts, this is D0213 on the Bid Form	Hunter Potts, DHM	12/22/25
3	GCUC	Grant	Will this project be owner paid materials?	Only owner purchased materials on the RIF Grant funded parts, D0213 of Bid Form	Hunter Potts, DHM	12/22/25
4	GCUC	Grant	Also how many copies of the bid are to be submitted?	1 original is fine along with two copies of the bid form.	Hunter Potts, DHM	12/22/25
5	Arris	Civil	Are there details/specs for the desired splash pad for the Cottondale Hurricane Michael Project?	See attachment labeled: RFI #5 - 01800 - Aquatic Playground Specs - Crossroads Park Approved Vendor: Struthers Recreation - John Kilpatrick, Project Manager john@struthersrec.com 205.663.5058/1.800.221.8869 Cell: 205-368-9279		12/30/25
6	Arris	Grant	Are you requiring a GC to bid on all parts or are you allowing site guys to bid parking lot parts and electricians to bid generator parts?	A GC is not required to bid on all parts. Trade specific contractors i.e. site and/or electrical may bid on only parts they are licensed to work on. Note from Bid Form <i>"The Owner reserves the right to award only select parts and not all parts, or reject all bids. Contractors may bid on all Parts or only on one or more Parts. The Owner may award all Parts to one contractor or individual Parts to different Contractors based upon what is in the best interest of the Owner including consideration of deductive alternatives. Contractor's bid should be a stand alone bid for each Part."</i>		12/30/25
7	Arris	Grant	Are you going to award the lowest combination of all parts combined or potentially award individual parts to different bidders?	See Note from Bid Form <i>"The Owner reserves the right to award only select parts and not all parts, or reject all bids. Contractors may bid on all Parts or only on one or more Parts. The Owner may award all Parts to one contractor or individual Parts to different Contractors based upon what is in the best interest of the Owner including consideration of deductive alternatives. Contractor's bid should be a stand alone bid for each Part."</i>		12/30/25
8	JNB Contracting	Civil	Fence Specification for Plan Sheet G1.2 (Generator Enclosure)?	Schedule 40 Fence: Line Posts: 2 3/8" O.D., Terminal/End/Corner; 3" O.D., Line Fabric: 9GA x 2" Galvanized Mesh, Top rail: 2" O.D., Middle Rail: 2" O.D, Bottom Rail: 2" O.D Vinyl Infill Acceptable	Hunter Potts, DHM	12/30/25
9	JNB Contracting	Civil	Fence Specification for Plan Sheet C11?	<u>Dog Park Fence/Stormwater Fence:</u> Black Sch. 40 - 4FT Tall Chain Link Posts: 2 3/8" O.D. Terminal/End/Corner; 1 7/8" O.D. Line Fabric: 9GA x 2" Black Vinyl Coated Mesh Top rail: 1 5/8" O.D. Middle Rail: 1 5/8" O.D Bottom Rail: 1 5/8" O.D Post Caps: Dome Style Ties: 9GA Aluminum Footings: Terminal posts 42" deep x 12"; Line Posts 36" x 10"; Concrete: 3000 PSI	Hunter Potts, DHM	12/30/25

10	JNB Contracting	Civil	Fence Specification for Plan Sheet LS1?	DHM to Field Verify, will provide results.	Hunter Potts, DHM	12/30/25
----	--------------------	-------	---	--	----------------------	----------