

ELECTRICAL SYMBOLS/ABBREVIATION

TAG LEGEND ITEM #

SYMBOLS	ABBREVIATIONS
	JB JUNCTION BOX (JB)
	CP CORD & PLUG
	EL ELEVATION ABOVE FINISHED FLOOR
	A AMPERES
	V VOLTS
	W WATTS
	PH PHASE
	AFF ABOVE FINISHED FLOOR
	DFA DOWN FROM ABOVE
	BTB BRANCH TO CONNECTION POINT AND CONNECT EQUIP.
	SU STUB UP ABOVE FINISHED FLOOR
	HP HORSE POWER
	KW KILLOWATTS
	DC DIRECT CONNECTION
	FEC FOOD SERVICE EQUIPMENT CONTRACTOR
	EX EXISTING

- NOTES**
- ALL ELECTRICAL OUTLETS SHOWN ON THIS PLAN ARE FOR FIXTURES SPECIFIED AS FURNISHED BY THE KITCHEN EQUIPMENT CONTRACTOR. FOR FURTHER BUILDING ELECTRICAL REQUIREMENTS (TELEPHONES, CLOCKS, SIGNS, EXHAUST FAN SWITCHING, ETC.) SEE OTHER PLANS
 - ALL DIMENSIONS GIVEN ARE IN FEET AND INCHES AND ARE FROM CENTERLINES AND/OR FINISHED WALLS. ELEVATIONS GIVEN ARE FROM FINISHED FLOOR TO CENTERLINE OF OUTLET. ALL ROUGH-INS SHOWN ARE TO BE RUN INSIDE WALLS (EXCEPT STUB-UPS). LOCATION INDICATES POINT OF EXIT FROM WALLS, CEILINGS OR FLOORS. ALL CONVENIENCE OUTLETS ARE TO SET HORIZONTALLY. ALL 120 VOLT OUTLETS NOT DESIGNATED WITH SPECIFIC LOADS TO BE RATED AT 20.0 AMPS.
 - ELECTRICIAN TO CONNECT ALL ELECTRICAL EQUIPMENT AND FIXTURES AS REQUIRED BY THE SPECIFICATIONS. ALL ELECTRICAL OUTLET COVER PLATES ARE TO BE STAINLESS STEEL AND ARE TO BE FURNISHED BY THE ELECTRICIAN, AS WELL AS THE RECEPTACLE, UNLESS OTHERWISE SPECIFIED IN THE ITEM SPECIFICATIONS. KITCHEN EQUIPMENT SUPPLIER TO FURNISH A GALVANIZED JUNCTION BOX IN THE FIXTURE CUTOUT TO RECEIVE THE RECEPTACLE, UNLESS OTHERWISE NOTED. ALL DISCONNECT SWITCHES REQUIRED ARE TO BE FURNISHED AND INSTALLED BY THE ELECTRICIAN AT TIME OF INSTALLATION
 - ALL WORK TO BE PERFORMED IN FULL ACCORDANCE WITH ALL APPLICABLE CODES RELATING TO HOOK-UP, INSTALLATION AND WIRING OF EQUIPMENT. OMISSIONS OR ERRORS ON THE SCHEDULE DO NOT RELIEVE THE ELECTRICIAN FROM COMPLETE FINAL CONNECTION RESPONSIBILITY.
 - IF ELECTRICAL OUTLETS AND/OR RECEPTACLES ARE CHANGED FROM "STUB-UP" TO "WALL-MOUNTED", THE "WALL-MOUNTED" OUTLETS AND/OR RECEPTACLES ARE TO BE SET AT 12" A.F.F.
 - ELECTRICAL CONDUIT TO BE PROVIDED & INSTALLED BY ELECTRICAL CONTRACTOR

FOODSERVICE EQUIPMENT ELECTRICAL SCHEDULE

REVISION	ITEM NUMBER	DESCRIPTION	REQUIREMENTS							REMARKS		
			VOLTS	PHASE	AMPS			DIRECT	PLUG TYPE		AFF	
	H1	EXHAUST HOOD SYSTEM										
		EXHAUST HOOD - LIGHT CIRCUIT	120	1	15 CKT				X		FLEX TO AUTO FAN CONTROL BOX(SEE SUBMITTAL DRAWINGS)	
		EXHAUST HOOD - CONTROL CIRCUIT	120	1	15 CKT				X		FLEX TO AUTO FAN CONTROL BOX(SEE SUBMITTAL DRAWINGS)	
	EF 1A	EXHAUST HOOD - EXHAUST FAN	208	3	4.8				X		FLEX TO AUTO FAN CONTROL BOX(SEE SUBMITTAL DRAWINGS)	
	EF 1B	EXHAUST HOOD - EXHAUST FAN	208	3	4.6				X		FLEX TO AUTO FAN CONTROL BOX(SEE SUBMITTAL DRAWINGS)	
	SF 1A	EXHAUST HOOD - MAKE-UP AIR FAN	208	3	15				X		FLEX TO AUTO FAN CONTROL BOX(SEE SUBMITTAL DRAWINGS)	
	WI1	WALK IN COOLER (LIGHTS AND DOOR HTR)	120	1	20.0				X		FLEX TO CONNECTION POINT (VERIFY WITH OWNER)	
	WI 1.1	WALK IN COOLER EVAPORATOR COIL	120	1	1.8				X		FLEX TO CONNECTION POINT (VERIFY WITH OWNER)	
	WI 1.2	WALK IN COOLER CONDENSING UNIT	208/230	1	15.0				X		FLEX TO CONNECTION POINT (VERIFY WITH OWNER)	
	WI 1.3	WALK IN FREEZER EVAPORATOR COIL	208/230	1	15.0				X		FLEX TO CONNECTION POINT, E.C. TO WIRE IN DEFROST	
	WI 1.4	WALK IN FREEZER CONDENSING UNIT	208/230	1	21.0				X		FLEX TO CONNECTION POINT (VERIFY WITH OWNER)	
	WI 1.5	WALK IN FREEZER (LIGHTS AND DOOR HTR)	120	1	20.0				X		FLEX TO CONNECTION POINT (VERIFY WITH OWNER)	
	1	STEAMER FLOOR MODEL, GAS	120	1	2.0					X	18"	NEMA 5-15P
	2	CONVECTION OVEN, GAS	120	1	3.5					X	18"	NEMA 5-15P
	4	REFRIGERATED EQUIPMENT STAND	120	1	2.3					X	18"	NEMA 5-15P
	8	FREEZER REACH IN	120	1	3.7					X	18"	NEMA 5-15P
	9	STEAM TABLE, 4 WELL	120	1	16					X	18"	NEMA 5-30P
	11	REFRIGERATED PREP TABLE	120	1	2.3					X	18"	NEMA 5-15P
	12	REFRIGERATOR, UNDERCOUNTER	120	1	2.3					X	18"	NEMA 5-15P
	15	HEAT LAMP	120	1	15.0				X		84"	FLEX TO CONNECTION POINT
	17	SODA DISPENSER W/ ICE BIN	120	1	5.0					X	48"	NEMA 5-15P VERIFY SPECIFICATIONS WITH PURVEYOR
	19	COFFEE BREWER	120	1	13.3					X	48"	NEMA 5-15P
	20	TEA BREWER	120	1	14.4					X	48"	NEMA 5-15P
	22	BAG IN BOX RACK	120	1	5.0					X	18"	NEMA 5-15P
	26	DISHWASHER	120	1	30					X	18"	FLEX TO CONNECTION POINT
	28	ICE MACHINE W/ WATER FILTER	208/230	1	26.1					X	72"	FLEX TO CONNECTION POINT
	B2	REFRIGERATOR, KEG TOWER	120	1	2.8					X	14"	NEMA 5-15P
	B6	ISLAND OASIS	120	1	15.0					X	14"	NEMA 5-15P (VERIFY SPECS WITH PROVIDER)
	CO1	CONVENIENCE OUTLET			15.0					X	48"	NEMA 5-15P
	CO2	CONVENIENCE OUTLET			15.0					X	30"	NEMA 5-15P

GENERAL PLUMBING NOTES

- PLUMBER TO PROVIDE BACKFLOW PREVENTER IN SUPPLY LINE TO ALL EQUIPMENT NEEDED PER LOCAL CODES
- PLUMBER TO SPECIFY AND LOCATE EQUIPMENT AND UTILITIES FOR THESE LOCATIONS
- PLUMBER TO CONNECT ALL WATER LINES, GAS LINES, WASTE LINES, ETC. TO FULLY CONNECT ALL EQUIPMENT AND RUN CONDENSATE LINES IN SOLID MATERIAL (NO FLEX HOSES) FROM UNITS TO DRAINS AND THESE LINES TO BE NO SMALLER THAN THE STUB-OUT OF THE FIXTURE. PLUMBER TO PROVIDE GATE VALVES ON ALL WATER AND GAS LINES, ALL VALVES, CUT-OFFS, TRAPS, HYDROSTATIC SHOCK ELIMINATORS PRESSURE REGULATORS AND MATERIALS NECESSARY TO CONNECT ALL LINES, UNLESS OTHERWISE SPECIFIED IN THE ITEM SPECIFICATIONS. FAUCETS, DRAIN OUTLET FITTINGS IN FIXTURES AND SPECIALTY ITEMS ARE TO BE FURNISHED BY THE KITCHEN EQUIPMENT CONTRACTOR AS OUTLINED IN THE ITEM SPECIFICATIONS. ALL WORK TO BE PERFORMED IN FULL ACCORDANCE WITH ALL APPLICABLE CODES RELATING TO INSTALLATION AND HOOKUP OF EQUIPMENT OMISSIONS OR ERRORS ON THE SCHEDULE DO NOT RELIEVE THE PLUMBING CONTRACTOR FROM COMPLETE FINAL PLUMBING RESPONSIBILITY
- ALL OUTLETS AND CONNECTIONS SHOWN RELATE TO KITCHEN EQUIPMENT ONLY. REFER TO ARCHITECTURAL/ENGINEERING PLANS FOR ADDITIONAL REQUIREMENTS
- ALL DIMENSIONS GIVEN ARE FROM COLUMN CENTERLINES AND/OR FINISHED WALLS AND ARE IN FEET AND INCHES. ELEVATIONS GIVEN ARE FROM FINISHED FLOORS. ALL ROUGH-INS SHOWN ARE TO BE RUN INSIDE WALLS (EXCEPT STUB-UPS) LOCATIONS INDICATE POINT OF EXIT FROM WALLS, CEILINGS OR FLOORS
- ALL FLOOR DRAINS TO SET 1/2" BELOW FINISHED FLOOR UNLESS OTHERWISE NOTED. DO NOT SLOPE FLOORS SO CLOSE TO DRAINS AS TO CREATE "PITS" OR "DIPS" IN FLOOR. MINIMUM RADIUS OF SLOPE TO BE 24" FROM CENTERLINE OF DRAIN
- ALL DRAINS ARE FOR REFERENCE ONLY SEE PLUMBING DRAWINGS FOR TYPE AND LOCATION REQUIRED

NOT FOR CONSTRUCTION

THIS DRAWING IS RELEASED FOR PRELIMINARY REVIEW ONLY. THIS DRAWING IS NOT TO BE USED FOR DESIGN OR CONSTRUCTION PURPOSES PENDING OWNER, ARCHITECT AND/OR CONSULTANT'S FINAL APPROVAL OF EQUIPMENT AND DESIGN.

PROJECT MANAGER:
ISSUE DATE:

PROJECT:
 APPROVED
 APPROVED AS NOTED
 REVISE AND RESUBMIT

SIGNATURE: _____
TITLE: _____
DATE: _____

OWNER: _____

SEAL: _____

PIER.PARK PROJECT

PANAMA.CITY,FL

REVISIONS:

NOTES:

ISSUED FOR: _____
PRELIMINARY
DATE: 01-27-2026

SHEET TITLE:
ELECTRICAL SCHEDULE

© 2026 THESE DOCUMENTS ARE THE PROPERTY OF KITCHEN EQUIPMENT & SUPPLY CO., INC. THEY MAY NOT BE ALTERED OR REPRODUCED WITHOUT WRITTEN CONSENT.

DATE: 02/26/26
SCALE: NTS
DRAWN BY: ZY
CHECKED BY:
JOB NO.:

FS1

Kitchen Equipment & Supply Co.
Panama City, FL 32407
Panama City, FL 32407
Panama City, FL 32407
850-545-1833
850-545-1833
850-545-1833