

SUPPLEMENT 1

Northside Elementary School Renovations

Allstate Construction, Inc.

June 12, 2026

Electrical Clarification

1. The following markup Supplement #1-Electrical 908 (dated 6/12/2026) has been posted to plan room website.
 - a. The panels "G1D, M1-A, K1A", and the transformer "T-M1A" listed on the Single Line Power Diagram (E6.02) and the Panel Schedule (E6.06) for RM 908 are mislabeled on sheet E1.32 in RM 908. They currently are shown as "E, F, KA" and the transformer "T". These panel designations will change to what is shown in the Riser Diagram (E6.02) and the Panel Schedule (E6.06). See pdf mark-up Supplement #1.

The bid date remains June 17, 2026 2:00 pm CST.

END OF SUPPLEMENT

Supplement #1
6/12/2026

