



Condition Index Detail Report



Tyndall AFB (XLWU)

00462 - PMEL LAB TYNDALL AFB SITE # 1 (XLWU00001)

System	Component	Section Description	Building CI (BCI)	System CI (SCI)	Comp CI (BCCI)	Section CI (CSCI)	Section Paint CI (CCI)	Last Inspection	Last Date
D30 HVAC									
	D3040 DISTRIBUTION SYSTEMS	AIR HANDLER EAST D304008 AIR HANDLING UNITS Central Station - 30000 CFM, VAV	80	66	56	61 / 52		21-Dec-2023	
	D3040 DISTRIBUTION SYSTEMS	AIR HANDLER WEST D304008 AIR HANDLING UNITS Central Station - 10000 CFM	80	66	56	61 / 52		21-Dec-2023	
	D3040 DISTRIBUTION SYSTEMS	CHILLED WATER PUMP EAST D304006 CHILLED WATER DISTRIBUTION SYSTEMS Circulating Pump, End Suction - 3" size, 5 HP, to 225 GPM	80	66	56	71 / 60		21-Dec-2023	
	D3040 DISTRIBUTION SYSTEMS	CHILLED WATER PUMP WEST D304006 CHILLED WATER DISTRIBUTION SYSTEMS Circulating Pump, End Suction	80	66	56	80 / 71		21-Dec-2023	
	D3040 DISTRIBUTION SYSTEMS	Exterior Bldg EA fans D304007 EXHAUST SYSTEMS Fan System, Wall Exhaust	80	66	56	88 / 73		21-Dec-2023	
	D3040 DISTRIBUTION SYSTEMS	HOT WATER PUMP D304003 HOT WATER DISTRIBUTION SYSTEMS Circulating Pump, End Suction	80	66	56	88 / 81		21-Dec-2023	
	D3060 CONTROLS & INSTRUMENTATION	AIR COMPRESSOR D306003 PNEUMATIC CONTROLS Air supply for pneumatic, tank mounted duplex compressor	80	66	50	88 / 72		21-Dec-2023	
	D3060 CONTROLS & INSTRUMENTATION	DDC Panel D306002 ELECTRONIC CONTROLS D.D.C controller, mechanical room, 32 point	80	66	50	61 / 38		21-Dec-2023	