

## ITB RLA002- Addendum 1

Question: Would like to know whether the existing metal ductwork in the attic contains internal duct liner (insulation on the inside of the duct) or whether the insulation is installed only on the exterior of the duct. Whether the existing metal ductwork contains internal insulation and, if known, any information regarding its condition?

Answer: All the existing duct is metal duct with exterior insulation that is noted on the drawings to be cleaned. I have attached some pictures of the duct for the contractor to reference.



