

ReliantSouth Note

The the WP plugs on the porch columns are hereby deleted.

KEYNOTES

- 1 EC TO INSTALL 3#4CU, 1#8CU GND IN 1'-1/4"C.
- 2 EC TO INSTALL 3#8CU, 1#10CU GND IN 1"C. =
- 3 PER MECHANICAL DESIGN, UNIT TO BE FURNISHED WITH DISCONNECT. EC TO FIELD-COORDINATE WITH MECHANICAL CONTRACTOR FOR EXACT LOCATION OF DISCONNECT.
- 4 PER MECHANICAL DESIGN, UNIT TO BE FURNISHED WITH UNPOWERED 120V GFCI CONVENIENCE OUTLET. EC TO FIELD-COORDINATE WITH MECHANICAL CONTRACTOR FOR EXACT LOCATION OF CONVENIENCE OUTLET.



ELECTRICAL POWER PLAN
SCALE: 3/32" = 1'-0"



Design - Build Contractor

230 West 5th Street
Panama City, FL 32401
(850) 215-5540

**SPEC 2 AT WEST BAY TOWN
CENTER**
8411 WEST BAY PKWY
PANAMA CITY BEACH, FL 32413

REVISION

#	DESCRIPTION	DATE

Designed By:
A.DAVIS

Drawn BY:
E.USI

**ELECTRICAL POWER
PLAN**

E100

07/02/2026



Florida CA Number: 27825
Anthony L. Davis, PE
Florida License Number: 57419
850.526.3447 / 334.209.0212
Project Number: 2026-023